



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Cedar Grove #9103 North End School, 122 Stevens Ave, Cedar Grove NJ
PAS Project ID : P24-10026

Matrix : Drinking Water
Report Date : 9/12/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-10026-01	NE-1-S-01-A	Lead	1.99 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/28/24 06:06	9/9/24 13:18
P24-10026-02	NE-1-S-02-A	Lead	1.50 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/28/24 06:07	9/9/24 13:22
P24-10026-03	NE-1-BF-02-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/28/24 06:08	9/9/24 13:26
P24-10026-04	NE-1-S-03-A	Lead	3.44	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/28/24 06:11	9/9/24 13:38
P24-10026-05	NE-1-BF-03-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/28/24 06:14	9/9/24 13:42
P24-10026-06	NE-1-WC-02-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/28/24 06:15	9/9/24 13:46
P24-10026-07	NE-1-WC-03-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/28/24 06:17	9/9/24 13:50
P24-10026-08	NE-1-BF-01-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/28/24 06:17	9/9/24 13:54
P24-10026-09	NE-8-28-FB-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/28/24 00:00	9/9/24 13:58

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Garden State Environmental
 Address: 555 S. Broad St.
 Glen Rock, NJ 07452
 Phone: (201) 652-1119 Office

School Name: Cedar Grove #9103 North End School
 School Address: 122 Stevens Avenue Cedar Grove NJ
 Sampled By: *Jim Morley*
 Print Name: Michael Blaney
 RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date / Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Protent	# Container	Class or Plastic	Analysis	LAB ID
NE-1-S-01-A Teacher's Room	8/28/24 6:08am	DW	Grab	no	no	1	250 ml Plastic	Lead	PS4-10026-01
NE-1-S-02-A Nurse	6:07am	DW	Grab	no	no	1	250 ml Plastic	Lead	02
NE-1-BF-02-A Outside Room 102	6:08am	DW	Grab	no	Yes	1	250 ml Plastic	Lead	03
NE-1-S-03-A Media Center	6:11am	DW	Grab	no	no	1	250 ml Plastic	Lead	04
NE-1-BF-03-A Outside Exit 5E	6:14am	DW	Grab	no	Yes	1	250 ml Plastic	Lead	05
NE-1-WC-02-A Gym Hall Left	6:15am	DW	Grab	no	Yes	1	250 ml Plastic	Lead	06
NE-1-WC-03-A Gym Hall Right	6:17am	DW	Grab	no	Yes	1	250 ml Plastic	Lead	07
NE-1-BF-01-A Gym Hall Right	6:17am	DW	Grab	no	yes	1	250 ml Plastic	Lead	08
NE-8-28-FB-A Field Blank	-	DW	Grab	-	-	1	250 ml Plastic	Lead	09
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of 1

Deliverables: PDF Std. PDF Reduce PDF Full EDD Date/Time Preserved with HNO3: 17:30 9/4/24

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify) :

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Michael Blaney	<i>Jim Morley</i>	GSE	9/3/24 1140
Received:	<i>Perry Hodges</i>	<i>Perry Hodges</i>	<i>YAC</i>	8/30/24 @ 3:30pm
Relinquished:	<i>Bob Matthews</i>	<i>Bob Matthews</i>		9/4/24 9:30
Received:				
Relinquished:				
Received:				