



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Cedar Grove #9103, South End School, 116 Harper Terrace, Cedar Grove NJ
PAS Project ID : P24-10027

Matrix : Drinking Water
Report Date : 9/13/2024

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P24-10027-01	SE-1-S-01-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/29/24 06:07	9/9/24 14:02
P24-10027-02	SE-1-S-02-A	Lead	1.02 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/29/24 06:09	9/9/24 14:06
P24-10027-03	SE-1-BF-02-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/29/24 06:11	9/9/24 14:25
P24-10027-04	SE-1-S-03-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/29/24 06:13	9/9/24 14:29
P24-10027-05	SE-1-BF-03-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/29/24 06:15	9/9/24 14:33
P24-10027-06	SE-1-WC-02-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/29/24 06:17	9/9/24 14:37
P24-10027-07	SE-1-BF-01-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/29/24 06:18	9/9/24 14:41
P24-10027-08	SE-8-29-FB-A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/29/24 00:00	9/9/24 14:45

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Garden State Environmental
Address: 555 S. Broad St.
Glen Rock, NJ 07452
Phone: (201) 652-1119 Office

School Name: Cedar Grove #9103 South End School
School Address: 116 Harper Terrace Cedar Grove NJ
Sampled By: *Tim Momy*
Print Name: Michael Blaney
RESULTS TO: labreports@gseconsultants.com

Sample ID Location	Date / Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
SE-1-S-01-A Teacher's Room	8/29/24 6:07am	DW	Grab	no	no	1	250 ml Plastic	Lead	024-10037-01
SE-1-S-02-A Nurse	6:09am	DW	Grab	no	no	1	250 ml Plastic	Lead	02
SE-1-BF-02-A Outside Room 103	6:11am	DW	Grab	no	Yes	1	250 ml Plastic	Lead	03
SE-1-S-03-A Media Center	6:13am	DW	Grab	no	no	1	250 ml Plastic	Lead	04
SE-1-BF-03-A Outside Room 118	6:15am	DW	Grab	no	Yes	1	250 ml Plastic	Lead	05
SE-1-WC-02-A Gym Hall Exit 5E	6:17am	DW	Grab	no	Yes	1	250 ml Plastic	Lead	06
SE-1-BF-01-A Gym Hall Exit 5E	6:18am	DW	Grab	no	Yes	1	250 ml Plastic	Lead	07
SE-8-29-FB-A Field Blank	-	DW	Grab	-	-	1	250 ml Plastic	Lead	08
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of 1

Deliverables: PDF Std. PDF Reduce PDF Full EDD Date/Time Preserved with: 17:30 9/4/24

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATION CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	Michael Blaney	<i>Tim Momy</i>	GSE	8/30/24 1140
Received:	<i>Ferry Habee</i>	<i>Benny Habee</i>	<i>YSL</i>	8/30/24 @ 3:30pm
Relinquished:				
Received:	<i>date mathews</i>	<i>D. M.</i>		9/4/24 9:30
Relinquished:				
Received:				